


UL CONSTRUCTION NO. 254

WIND-UPLIFT - CLASS 90 (SEE ITEM NO. 4)/ FIRE NOT INVESTIGATED



1	Metal Roof Deck Panels* "Snap-Clad"	No. 22 MSG or No. 24 MSG min. thickness coated steel panels. Panels 12 in. wide max., 10 in. wide min. 1-3/4 in. high at the ribs. Panels continuous over two or more spans. A bead of sealant may be used at panel side joints.	
2	Roof Deck Fasteners* (Panel Clips) "Snap-Clad Clip"	One piece assembly, 3-1/2 in. wide, 1-7/8 in. high. One panel clip located at each purlin intersection.	
3	Panel Fasteners (Screws)	Fasteners used to attach panel clips (item 2) to purlins to be No. 10-16 by 1 in. long No. 3 self-drilling point, No. 2 Phillips drive head, cadmium plated steel screws. Two screws per clip to be used, inserted through 1/4 in. diameter guide holes.	
4	Purlins	No. 16 MSG min. thickness steel (50,000 psi min. yield strength).	
		Spacing:	For 22 MSG thickness panels - 60 in. OC For 24 MSG thickness panels - 48 in. OC
		*Bearing the UL Classification Marking	

PETERSEN ALUMINUM CORPORATION

HQ: 1005 Tonne Road Elk Grove Village, IL 60007 P: 800-PAC-CLAD F: 800-722-7150

9060 Junction Drive Annapolis Junction, MD 20701 P: 800-344-1400 F: 301-953-7627

10551 PAC Road Tyler, TX 75707 P: 800-441-8661 F: 903-581-8592 102 Northpoint Parkway Acworth, GA 30102 P: 800-272-4482 F: 770-420-2533

1800 S. 7th Ave., Suite 130 Phoenix, AZ 85007 P: 833-750-1935 F: 602-254-6504

PAC-CLAD.COM SALES@PETERSENMAIL.COM

1885 Station Parkway NW, Suite B Andover, MN 55304 P: 877-571-2025 F: 866-901-2935