



1	Metal Roof Deck Panels* "Snap-Clad"	No. 22 MSG or No. 24 MSG min. thickness coated steel panels. Panels 12 in. wide max., 10 in. wide min. 1-3/4 in. high at the ribs. Panels continuous over two or more spans. A bead of sealant may be used at panel side joints.
2	Roof Deck Fasteners* (Panel Clips) "Snap-Clad Clip"	One piece assembly, 3-1/2 in. wide, 1-7/8 in. high. One panel clip located at each purlin intersection.
3	Panel Fasteners (Screws)	Fasteners used to attach panel clips (item 2) to purlins to be No. 10-16 by 1 in. long No. 3 self-drilling point, No. 2 Phillips drive head, cadmium plated steel screws. Two screws per clip to be used, inserted through 1/4 in. diameter guide holes.
4	Purlins	No. 16 MSG min. thickness steel (50,000 psi min. yield strength). Spacing: For 22 MSG thickness panels - 60 in. OC For 24 MSG thickness panels - 48 in. OC

*Bearing the UL Classification Marking